

R4082.2 More efficient HVAC equipment performance option.

Heating and cooling equipment shall meet one of the following efficiencies:

Centrally Ducted Systems

1. Greater than or equal to 95 AFUE natural gas furnace and 16 SEER2 in Climate Zones 5, 6, and 7 and 16.09 SEER2 in the other Climate Zones for air conditioner
- 2.

~~speed air source heat pumps in both centrally ducted and ductless systems.~~ The metrics of HSPF and SEER are being updated to the new metrics of HSPF2 and SEER2 that will be in effect when the 2024 IECC is adopted by jurisdictions (see 10 CFR 430.32).