International Energy Conservation Code
Consensus Committee-Residential

Draft Meeting Agenda (8/25/23 posting-update)

2:00 - 5:00 PM Eastern

Committee Chair:
Committee Vice Chair:

Copyright © 2021 International Code Council, Inc.

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code
Code Change Proposal Tracking Sheet

	RE2D-47-23 Floor alterations
	1647
	IECC RE
	R503.1.1.4
	SC rev
	Lucyna de Barbaro ldbarbaro@rtpittsburgh.org
	SC rev
	RE Existing Bldg

Motion to Disapprove
Reason statement: Proposal would likely significantly increase cost of construction contrary to its reason statement, is substantive rather than

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code

Code Change Proposal Tracking Sheet

	RE2D-46-23 Above-grade wall alteration
	1787
	IECC RE
	R503.1.1.3
	SC rev
	Amy Martino amartino@buildingsitesynergy.com
	SC rev
	RE Existing Bldg
	Motion AM: Add “as applicable” after “following” at the beginning of the section, remove “and” from the 1st sentence of item #1, and keep “continuous” in section #2

As Modified by the committee. 8/22/2023

R503.1.1.3 Above-grade wall alterations.

[illegible] alterations shall comply with the following as applicable

Copyright © 2021 International Code Council, Inc.

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code
Code Change Proposal Tracking Sheet

	RE2D-27-23 Air leakage reference
	1613
	IECC RE
	R405.4.2(1) table
	SC rev
	Theresa Weston holtweston88@gmail.com
	SC rev

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code
Code Change Proposal Tracking Sheet

	RE2D-33-23 Table R407.1 footnote ref change
	1611
	IECC RE
	R407.2 Table
	SC rev
	Greg Johnson gjohnsonconsulting@gmail.com
	SC rev

Copyright © 2021 International Code Council, Inc.

International

Copyright © 2021 International Code Council, Inc.

RE2D-37-23 Modification 1a

note: legislative edits are shown against PCD#2

Revise as follows:

TABLE R408.2 CREDITS FOR ADDITIONAL ENERGY EFFICIENCY

Portions of table not shown remain unchanged.

Measure Number	Measure Description
~~R408.2.3.1[c]~~ R408.2.3(8)[c]	Compact hot water distribution

Copyright © 2021 International Code Council, Inc.

Energy Efficiency Ratio (SEER2). Where multiple heating or cooling systems are installed serving different zones, credits shall be earned based on the weighted average of square footage of the a served by the system.

R408.2.3 Reduced energy use in service water-heating options.

For measure numbers R408.2.3(1) through R408.2.3(7), the installed hot water system shall meet one of the Uniform Energy Factors (UEF) or Solar Uniform Energy Factors (SUEF) in Table R408.2.3. For measure number R408.2.3(8), the ~~hw i~~ hot water distribution system shall comply with R408.2.3.1.

R408.2.4 More efficient duct thermal distribution system options.

R408.2.5 Improved air sealing and efficient ventilation system options.

The measured air leakage rate and ~~h~~ system shall meet one of the fo(n)p35o0 odwe .4nit

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code
Code Change Proposal Tracking Sheet

	RE2D-53-23 Remove Appendix RG
	1838
	IECC RE
	Appendix RG
	Eric Tate eric.tate@atmosenergy.com
	SC rev
	RE Econ, Model, Metric

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code
Code Change Proposal Tracking Sheet

	RE2D-54-23 Remove Appendix RH
	1839
	IECC RE
	Appendix RH
	Eric Tate eric.tate@atmosenergy.com
	SC rev
	RE Econ, Model, Metric
	Motion for Disapproval Gayathri Vijayakumar; 2nd Ben Edwards
	The Sub-Committee approved the addition of the Carbon Rating appendix in the last round to provide AHJs with options to shift the focus of their requirements to reducing GHG emissions, rather than just energy. The proponent didn't provide specific changes to resolve their objections to the existence of the optional Appendix. SC Action: Disapprove
	DISAPPROVE: 13 YES; 0 NO; 1 ABSTAIN
	August 15, 2023
	To Subcommittee To Advisory Group_____ To Consensus Committee_____X_____
	Affirmative_____ Negative_____ Table_____ To Subcommittee_____

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code

Copyright © 2021 International Code Council, Inc.

!" # $%&'

( ) * +* , " +

- . / (0$$!1’ ,)) -)23 2 -4 - 3 3 3 , 2, 2)53
! " # $ %' & ’

( ) * + , - , * *	. *)) / *) . +*	, , .)) . +*
%6 7	- 8 7 7 7 9 7 7 $	
	5 8 $	
	8 - % ($1$$	
	: (0	
	: ($($	
. 7 7	- 8 $	
	5 8 $	
	8 - % (1 7 7 $	
%6	- 87 $	
	5 8 $	
	8 - % ($1$$	
	- 87 $	
	5 8 $	
	8 - % ($1$$	
	- 8 7 $	
	5 8 $	
	: (0	
	: ($($	
	- 86 7 1 (($	
	- 8 $	

	7 % < % 6 % 7 8 1 ! (’ 7 % < % 7 8 7 % 8 8 $	" 2A % 8 % ÙÅ°¿a/ 8 p— À

	7 7 87 $	$

	" C «ł æ q "À° q X4 — —	

$	7 % 7 7 % & 8

	: B B
7 8	
	: - & $
	: ! & $
	: ! % 6 % 7 ’H % 6 % 7 J ($D B % 7 % 7 ’$
	: ! % 6 % 7 ’H % 6 % 7 J 7 ’ ($DE 7 6 $
7 8	
	- % 7 7 % $
	% 6 % 7 % 7 7 $
	. 7 % 7 % 7 $
	7 7 7 " 7 $

$	- 7 % % 7 < 6 ! S 7 T 6 % 7 $

1$	7 7 % 7 7 $
$	- 7 7 @¡ p— ‘

7 % $, 7 S % T % % S % T 7 - % ($ 1 $ $ - % % % % % 7 ! % % 7 ’ $) % % ET % < % 6 $ % % 7 6 7 % 7 - % ($ 1 $ $ = % % 7 6 < 7 C 7 % 7 6 = 7 7 6 7 $

%

- 7 $

- 7

- % 7 < % 6 % 7 (1) $ - $ 6 % % 6 $

Copyright © 2021

RE2D-38-23 Modification

IECC RE: Table R408.2, R408.2.1.3, Table R408.2.1.3, R408.2.1.3.1

Modification replaces the original proposal. Legislative edits are shown against Public Comment Draft #2.

Revise as follows:

TABLE R408.2

CREDITS FOR ADDITIONAL ENERGY EFFICIENCY

		Climate Zone 0 & 1	Climate Zone 2
R408.2.1.3(1)	Roof solar reflectance index (roof is part of the building envelope and directly above cooled, conditioned space)	1	~~1~~ 0
R408.2.1.3(2)	Roof solar reflectance index (roof is above an unconditioned space that contains a duct system)		

Copyright © 2021 International Code Council, Inc.

1.4 Above-roof decks or walkways.

1.5 Skylights.

1.6 HVAC systems and components, and other opaque objects mounted above the roof.

2. Portions ~~of the roof~~ shaded during the peak sun angle on the summer solstice by permanent features of the building ~~or by~~ permanent features of adjacent buildings, or natural objects.

3. Portions ~~of roofs~~ that are ballasted with a minimum stone ballast of 17 pounds per square foot (74 kg/m^2) or 23 psf (117 kg/m^2) pavers.

~~4. Roofs where not less than 75 percent of the roof area complies with one or more of the exceptions to this section.~~

The three-

Copyright © 2021 International Code Council, Inc.

$R_{aged} = [0.2 + 0.7(R_{initial} – 0.2)]$ (Equation 4-4)

where:

R_{aged} = The aged solar reflectance.

$R_{initial}$ = The initial solar reflectance determined in accordance with ASTM C1549, ASTM E903, ASTM E1918, or ~~with CRRC-S100~~ CRRC S100.

Reason Statement

This Modification addresses the following shortcomings in Section R408.2.1.3:

1. **Section R408.2.1.3 does not explicitly state what percentage of roof area must comply with the SRI requirements to earn credit.**

   When this section was added in PCD #1, it was silent as to the percentage of roof area required for credit. Presumably, 100% was the default.

   In PCD #2, exception language was imported from Section C402.4 in the Commercial code. A percentage is buried in Exception 4. Per the proponent, the intention was not to provide a roof area compliance percentage, but rather to prevent false claiming of credit.

   Moreover, although the two sections have similarities, Section C402.4 is a requirement, while this section is an option.

   MODIFICATION:

   Explicitly states a required percentage and does so outside the exceptions.

2. **The required**

Copyright © 2021 International Code Council, Inc.

Although Exception 4 was not intended to provide a compliance percentage, as PCD #2 reads, Exception 4 does exactly that.

What is that percentage? Exception 4 requires some work to decipher:

> In C402.4, where H75% of the roof area falls into one or more of the exceptions, the entire roof is exempt from the requirement. In other words, the requirement must be met if >25% of the roof area does not fall into one or more of the exceptions.
>
> But R408.2.1.3 is not a requirement; it's an optional measure. So, here, the exception language means: The roof can qualify for credit if >25% of the roof area does not fall into one or more of the exceptions.
>
> In other words, a roof qualifies for credit if 26% of the roof area meets the SRI and 74% does not.

In the context of this section, Exception 4 translates to: credit can be earned if just over 25% of roof area complies with the required SRI.

In PNNL's analysis, it was assumed **100%** of roof area met the required SRI. Modeled at 100% compliance, measure number R408.2.1.3(2) achieved one point by the slimmest of margins – 0.04% in Climate Zone 1 and 0.02% in Climate Zone 2. If PNNL had modeled, for example, 30% of roof area (or even a considerably higher percentage), the measure would not have met the 0.50 threshold to be rounded up to one point.

MODIFICATION:

To earn credit, 95% of roof area must meet the required SRI.

(Although 100% of roof area was modeled, a 5% allowance is provided for items such as HVAC equipment on the roof.)

3. The required SRIs must correlate with the credits in Table R408.2. The steep slope SRI does not.

In PCD #2, the µ] o } ^ Z /] H í ò v Z µ] o } ` o } ^ Z /] H ó

Copyright © 2021 International Code Council, Inc.

Cost Impact

The code change proposal will neither increase nor decrease the cost of construction. This is an optional measure that presumably will not be chosen unless it is cost effective.

Copyright © 2021 International Code Council, Inc.

International Energy Conservation Code
Code Change Proposal Tracking Sheet

	RE2D-44-23 Energy efficient appliances edit
	1703
	IECC RE
	R408.2.6
	Alex Smith asmith@npga.org
	SC rev
	RE Econ, Model, Metric

Copyright © 2021 International Code Council, Inc.

RE2D-44-23 Modification by Proponent was further modified in blue by SC to remove sentence on compact appliances and wordsmith 1st sentence

IECC RE: R408.2.6, TABLE R408.2.6 æ

This Modification replaces the original proposal. The proposed changes, with one exception, are the same as in the original proposal; they are just moved around. Legislative edits are shown against Public Comment Draft #2. Additional information is provided in the Reason Statement.

Revise as follows:

R408.2.6 Energy efficient appliances. ~~All a~~Appliances of each of the types listed in Table R408.2.6

Copyright © 2021 International Code Council, Inc.

Reason Statement

A new version of R408.2.6 was approved in the last round. Like many new code sections, it has some loopholes and requires some clarification.

Compact Appliances

This is the annual energy use data for Energy Star Certified compact refrigerators and dishwashers:

Energy Star Certified Compact Appliances Annual Energy Use Ranges (kWh/yr)			
Energy Star Certified Appliance	U.S. Federal Standard	Energy Star	Energy Star Most Efficient
Compact Refrigerator	228 to 580	106 to 470	

Copyright © 2021 International Code Council, Inc.

Prevent Future Installation of Less-Efficient Clothes Washers at Plumbed Locations

In some buildings, some (typically the larger) dwelling units are plumbed for washers and common area laundry facilities are provided. Footnote "a" to Table R408.2 provides that washers must be installed in both the plumbed dwelling units and the common area(s). But that should be stated explicitly in this section. The idea is to avoid future (e.g., post-COO) installation of less efficient appliances in plumbed dwelling units.

The loopholes described above are closed by the proposed changes.

Clothes Washers Located Outside Dwelling Units

The phrase "Where dwelling units are not provided with laundry facilities" in Table R408.2.6 is commonly interpreted as 'where dwelling units are not provided with a common area laundry room.' That is not what the proponents intended. The proposed change conveys the proponents' intent.

Reference: IRC definition of "rough-in."

Appliance Types

The term "appliance types" is used three times. Its meaning is clarified by changing the left column heading in Table R408.2.6 to "appliance types."

Not less than three

"Not less than three appliance types . . ." is a remnant from PCD#1 when the Table contained four appliance types. Since there are now only three, to avoid confusion, that phrase has been replaced by "Each appliance type . . ."

Other Appliance Types

Copyright © 2021 International Code Council, Inc.

As currently drafted in PCD#2, the first sentence could

Copyright © 2021 International Code Council, Inc.