



International Energy Conservation Code  
HVACR Subcommittee  
Meeting Minutes foMarch

4. Proponent Steven Rosenstock presented RED 4299-22, and explained the proposal only modifies the exception to 90.1 and has been made in the commercial side as well and it changes the exception from solar to on-site renewable energy to allow multiple forms of onsite renewable energy to qualify to the exception. Sonny Richardson made a motion to accept. Gary Klein seconded. Group discussion. The chair opened the floor to vote, 10-0.
5. Proponent Tom Ortiz presented RED 300-22P1, PII regarding and in consultation with the pool and spa industry, a modification and exception for vapor retardant covers for pools shaped where there is no commercially available solutions. Ortiz explained the proposal in detail. Dean Potter made a motion to disapprove as modified. Gary Klein seconded. Considerable group discussion. The chair opened the floor to vote, 9-0-1. After discussion from the group about the vote for modification the proponent

D The cha (h)-6 (p) 1.8 (s) 1.5 (cc) 2e) 0.7 (l) 1.5 (o) 4.1 (o) 4 (r) 0.6 (h) - Td -4..7 (i) -1.

9. Proponent Gary Klein presented RED1315-22 and is an original proposal which added the AHRI standard to the list and explained the working group agreed to create a table instead of putting it in the language of the clause itself. This is the original language as modified. Gary Klein made the motion to approve as modified, Ben Rabe seconded. The chair opened the floor for discussion. Group discussion. The chair opened the floor to vote. 10-17
10. Proponent Greg Johnson asked to withdraw RED1314-22.
11. Proponent Gary Klein presented RED1314-22 regarding fixing the language of getting rid of the words about plan review and recommend incorporating into the commentary section. Klein made a motion to disapprove. Kevin Rose seconded. The chair opened the floor for discussion. Group discussion. The chair opened the floor to vote. 10-0
12. Proponent Ted Williams presented RED1315-22 regarding striking language related to gas fired storage water heaters equal to or under 55 gallons medium duty with a UEF with equal to or greater than .81. Williams explained the proposal in detail. Gary Klein suggested that we review RED1358 prior to voting on 355 because they are identical and it comes from AHRI and includes discussion about water heaters. Ted Williams agreed. The chair opened the floor to discuss RED1358. Proposal RED1358 was explained in detail. Ben Rabe proposed a friendly amendment borrowing from RED1357 which is editorial regarding storage volume. Gary Klein made a motion to modify proposal 358 with the friendly amendment. Group discussion to amend tables. Kyle Bergeron seconded. The chair opened the floor for discussion. Group discussion. The chair opened the floor to vote. 0-8. Gary Klein made a motion to disapprove RED1355 based on motions made on RED1358. Jennifer Amann seconded. The chair opened the floor for discussion. No discussion. The chair opened the floor to vote. 0-8
13. Proponent Eric Tate stated that proposal RED1356-22 is essentially the same as 355 and doesn't add anything at this point. Gary Klein made a motion to disapprove based on the decision made on 358. Dean Pottese seconded. The chair opened the floor for discussion. Discussion. The chair opened the floor to vote. 0-1
14. Proponent Steven Rosenstock presented RED1357-22 and explained an editorial change was made on 358 and asked to hear 357 to be heard after 358 at main committee. Gary Klein made a motion to disapprove. Dean Pottese seconded. The chair opened the floor for discussion. Group discussion. The chair opened the floor to vote. 0-19
15. Proponent Gary Klein presented RED1317-22 and discussed two parts of this proposal in regards the designation to the testing of the equipment is shown on the equipment. The second part is to modify the table to not allow any leakage greater than 4cfm per 100 square feet. Klein showed the recommendations from the work group. Klein made the motion to table this proposal to the April 3 meeting. Sonny Richardson seconded. The floor opened the floor for discussion. Group discussion. The chair opened the floor to vote. 0-09
16. Proponent Gary Klein presented RED1319-22 and showed the recommendation. Vladimir Kochk

17. Proponent Greg Johnson presented REB-22 by standing by the reason statement. Gary Klein asked to incorporate these edits into 285 or just to approve this and asked ICC to incorporate the edits when needed. Johnson agrees they integrate. Gary Klein makes the motion to approve. Sonny Richardson seconded. The chair opens the floor for discussion. No discussion. The chair opens the floor to vote:040
18. Greg Johnson explained RED-22 status regarding shared systems in residential building and says you should comply with the commercial code. Johnson explained proposal in detail. Group discussion.

19. Upcoming Meeting; April 3rd 2023, 11:00 EST-2:00 EST

20. Meeting adjourned at 2:04 EST.