

# RECPI-2-21

IRC: TABLE N1105.4.2(1)

Proponents: Richard Potts, representing IECC Residential Consistency and Administration Subcommittee (ieccreadmin@iccsafe.org)

## 2021 International Residential Code

Revise as follows:



- i. The factor for the compactness of the hot water distribution system is the ratio of the area of the rectangle that bounds the source of hot water and the fixtures that it serves (the "hot water rectangle") divided by the floor area of the dwelling.
1. Sources of hot water include water heaters, or in multiple-family buildings with central water heating systems, circulation loops or electric heat eh.